

SAN DIEGO GAS & ELECTRIC
GAS QUALITY
QUARTERLY SULFUR REPORT

	Hydrogen Sulfide Max (Grains/100scf)			Total Organic Sulfur Max (Grains S/100scf)		
	Rainbow	Oceanside	Otay	Rainbow	Oceanside	Otay
Pipeline System Receipt Point						
1/1/2025 - 3/31/2025	< 0.25	< 0.25	< 0.25	<0.75	<0.75	<0.75
4/1/2025 - 6/30/2025	< 0.25	< 0.25	< 0.25	<0.75	<0.75	<0.75
7/1/2025 - 9/30/2025						
10/1/2025 - 12/31/2025						

* Sulfur content meets California Public Utility Commission (CPUC) natural gas requirements as defined in General Order 58A.

Max of unaudited operational data. Data may be subject to adjustments and corrections. This is provided for information purposes only. SDG&E publication nor verbal representations thereof constitutes any statement, recommendation, endorsement, approval or guaranty (either express or implied) of any product or service. Moreover, SDG&E shall not be responsible for errors or omissions in this publication, for claims or damages relating to the use thereof, even if it has been advised of the possibility of such damages.