

## SDG&E June 15th, 2022

### Rulemaking (R.) 15-01-008 to Adopt Rules and Procedures Governing Commission Regulated Natural Gas Pipelines and Facilities to Reduce Natural Gas Leaks Consistent with Senate Bill 1371, Leno. In Response to Data Request, R15-01-008 - 2022 June Report Appendix 2 - Rev. 03/30/22

#### Notes:

Use a formula-derived value with the formula used in the Annual Emissions column. Do not use a copy and paste-as-value.

At the end of Annual Emissions Column, add a summation total in a cell for a column total, and then highlight orange.

Facilities emissions that are based on a population count times an emission factor (See Appendix 9 for guidance).

#### Transmission M&R Station Total Leaks and Emissions:

Number of Stations	Station Classification	Emission Factor (Mscf/yr/ <b>Station</b> )	Annual Emission (Mscf)	Explanatory Notes / Comments
14	T	1554.8	21,767.20	This includes stations that have Transmission to Distribution connections

Sum Total

21,767

## SDG&E June 15th, 2022

### Rulemaking (R.) 15-01-008 to Adopt Rules and Procedures Governing Commission Regulated Natural Gas Pipelines and Facilities to Reduce Natural Gas Leaks Consistent with Senate Bill 1371, Leno. In Response to Data Request, R15-01-008 - 2022 June Report Appendix 2 - Rev. 03/30/22

Note:

Use a formula-derived value with the formula used in the Annual Emissions column. Do not use a copy and paste-as-value.

At the end of Annual Emissions Column, add a summation total in a cell for a column total, and then highlight orange.

#### Transmission M&R Station Blowdowns:

ID	Geographic Location	Number of Blowdown Events	Annual Emissions (Mscf)	Explanatory Notes / Comments
NA	SDG&E Territory	14	0.28	Pressure Limiting Station Annual Inspection - Estimated avg. gas vented = 20 scf/insp Relief Valve Inspection at Transmission M&R Stations - Estimated avg. gas vented = 20 scf/insp (annual test with Nitrogen, gas vented is volume of
NA	SDG&E Territory	44	0.88	gas in valve)
NA	SDG&E Territory	18	0.54	Filter Changeout or Filter Inspection w/parts replacement - Estimated avg. gas vented = 30 scf/ea
NA	SDG&E Territory	1	0.025	Analyzers (25 scf/inspsection)
NA	SDG&E Territory	29	0.058	Controllers - Estimated avg. gas vented = 2 scf/insp
NA	SDG&E Territory	24	0.048	Workers - Estimated avg. gas vented = 2 scf/insp

Rulemaking (R.) 15-01-008 to Adopt Rules and Procedures Governing Commission Regulated Natural Gas Pipelines and Facilities to Reduce Natural Gas Leaks Consistent with Senate Bill 1371, Leno.  
In Response to Data Request, R15-01-008 - 2022 June Report  
Appendix 2 - Rev. 03/30/22

Notes:

The data collected on this sheet is for informational purposes and may not be included in the emissions inventory for 2020. The worksheet is designed to track actual emissions for future reference and to determine if an actual leak based emission accounting is feasible for M&R stations.

Use a formula-derived value with the formula used in the Annual Emissions column. Do not use a copy and paste-as-value.

At the end of Annual Emissions Column, add a summation total in a cell for a column total, and then highlight orange

The emissions captured on this tab represent the emissions associated with the operational design and function of the component. Any intentional release of natural gas for safety or maintenance purposes should be included on the Blowdowns worksheet.

**Transmission M&R Station Component Vented Emissions:**

ID	Geographic Location	Station Classification	Device Type	Bleed Rate	Manufacturer	Number of Days Emitting	Annual Emissions (Mscf)	Explanatory Notes / Comments
24	SDG&E	A3	P	I	Misc.	365	NA	Intermittent Bleed Pneumatic Devices emissions are included in Trans-to-trans Emission Factor of 1,554.8 Mscf/Station/Year

Rulmaking (R.) 15-01-008 to Adopt Rules and Procedures Governing Commission Regulated Natural Gas Pipelines and Facilities to Reduce Natural Gas Leaks Consistent with Senate Bill 1371, Leno.

In Response to Data Request, R15-01-008 - 2022 June Report

Appendix 2 - Rev. 03/30/22

The emissions captured on this tab represent the emissions associated with unintentional leaks that if repaired would not be leaking. If the component is releasing gas or "bleeding" as a result of its design or function, then it is not to be captured in this tab.

Transmission M&R Station Component Fugitive Leaks:								12/31/2021	1/1/2021			
ID	Geographic Location	Station Classification	Device Type	Bleed Rate	Manufacturer	Discovery Date (MM/DD/YY)	Repair Date (MM/DD/YY)	Number of Days Leaking	Emission Factor (Mscf/day/dev)	Annual Emissions (Mscf)	Explanatory Notes / Comments	Prior Survey Date (MM/DD/YY)
102541	92028 A3	C				2/17/2021	2/17/2021	47 NA	NA	NA	Component leaks at Transmission M&R Station	1/2/2021
107905	92111 A3	C				6/10/2021	6/10/2021	161 NA	NA	NA	Component leaks at Transmission M&R Station	6/12/2020
											NA	

## Appendix 2 - Rev. 03/30/22

Header column "Comment" boxes displayed below for reference.	
Column Heading	Description and Definition of Required Contents (IF not self-explanatory)
<b>Station Leaks and Emissions</b>	
Number of Stations	
Station Classification	D = direct sale T = transmission-to-transmissions interconnect  As revised in 2021, enter Farm Taps in Appendix 5
Emission Factor (Mscf/yr)	
Annual Emission (Mscf)	
Explanatory Notes / Comments	

<b>Blowdowns</b>	
ID	
Geographic Location	GIS, zip code, or equivalent
Number of Blowdown Events	
Annual Emissions (Mscf)	
Explanatory Notes / Comments	

<b>Component Vented Emissions</b>	
Geographic Location	GIS, zip code, or equivalent
Station Classification	A1 = above grade, pressure <100 psi A2 = above grade, pressure =100-300 psi A3 = above grade, pressure >300 psi B1 = below grade, pressure <100 psi B2 = below grade, pressure =100-300 psi B3 = below grade, pressure >300 psi
Device Type	C = connector O = open-ended line M = meter P = pneumatic device PR = pressure relief valve V = valve
Bleed Rate	L = low bleed I = intermittent bleed H = high bleed NA = not applicable
Manufacturer	
Number of Days Emitting	Because the emissions are a factor of design or function, these emissions counted for the entire year.
Annual Emissions (Mscf)	The emissions should be based on 365 days times the actual volume emitting if known, or the approved Emissions Factor.  Note whether the emissions are based on actual volumetric measures in the next column.
Explanatory Notes / Comments	

New Column - for type of M&R Station where emission located.

<b>Component Leaks</b>	
ID	

<b>Geographic Location</b>	GIS, zip code, or equivalent
<b>Station Classification</b>	A1 = above grade, pressure <100 psi A2 = above grade, pressure =100-300 psi A3 = above grade, pressure >300 psi B1 = below grade, pressure <100 psi B2 = below grade, pressure =100-300 psi B3 = below grade, pressure >300 psi
<b>Device Type</b>	C = connector O = open-ended line M = meter P = pneumatic device PR = pressure relief valve V = valve
<b>Bleed Rate</b>	L = low bleed I = intermittent bleed H = high bleed NA = not applicable
<b>Manufacturer</b>	
<b>Discovery Date (MM/DD/YY)</b>	List the actual discovery date.  If the leak was discovered in the year of interest, then we will assume the component was leaking from the beginning of the year for emissions reporting purposes, or prior survey date if surveyed previously within the year of interest.
<b>Repair Date (MM/DD/YY)</b>	
<b>Number of Days Leaking</b>	Assume Leaking from January 1 of subject year or prior survey date, whichever is later, thru the repair date (if repaired in year of interest) or December 31 of subject year, whichever is earlier.  For O&M discovered leaks, assume that the leak begins with the discovery date <u>thru</u> repair date or December 31st of subject year, whichever is earlier.
<b>Annual Emissions (Mscf)</b>	
<b>Explanatory Notes / Comments</b>	

New Column - for type of M&R Station where found.